

Industry & Facilities Division Inspection Certificate

CERTIFICATE

API Standard 607 7th Edition: 2016

The undersigned, Vincent Sheng acting with the scope of the contractual requirements entrusted to Bureau Veritas, certifies that the supply:

Valve Model

: Series F502

Valve Type

: 2PC Flanged End Ball Valve (Full Bore)

Valve Size

: 2 inch (DN 50) x 1piece

Pressure Rating

: Class 150

Drawing No.

: Z02Q80A0-3 ver.0

Body Material

: ASTM A890 CE3MN

Seat Material

: PTFE

Ball Material

: ASTM A351 CF8M

Stem Material

: SS316

Supplied by

: TRANSWORLD STEEL ENTERPRISE CO., LTD.

Tested by Metal Industries Research & Development Centre (MIRDC) and witnessed by Bureau Veritas, per API Standard 607 7th Edition: 2016 at Lung-Tan, Taiwan. Verified in conformity with the requirements of the standard mentioned above.

Client

: TRANSWORLD STEEL ENTERPRISE CO., LTD.

No. 34, Gongye 14th Rd., Dali Dist., Taichung City 412, Taiwan (R.O.C.)

Test Date

: 2 Nov. 2023

Test Report No. : T11211004-2

Qualified Range of Valves (according to Clause 7.3 ~ 7.4 of API Standard 607 7th Edition: 2016)

Valve Model

: Series F502

Pressure Rating

: Class 150: 300

Valve Size

: NPS 2 and below; 2 1/2; 3; 4 (DN 50 and below; 65; 80; 100)

Body Materials

: Duplex

Etabli à / Issued at	- Le / On	Signé par / Signed by	Signature / Signature
Taipei, Taiwan	17 Nov. 2023	Vincent Sheng	Virus Stray
rtificate No. : TPI23284-3	(TAIP		

^{*} This certificate must be read in conjunction with the test report No. T11211004-2 of MIRDC.

^{**} This certificate is subject to the terms of Bureau Veritas General Conditions of Service attached to the agreement signed by the applic